


AANSLITSHEMA – ECE TOUCH CONTROL



Instelling DIP-schakelaars

SW1		
Master	SW1-1	OFF
Slave	SW1-2	ON
SW2		
Standaard	SW2-1	SW2-2
0-10V ingaand signaal	OFF	OFF
	OFF	ON

NHS Luchtgordijnen

Binnenweg 6, 5683 PR Best, **T** +31 (0)499 870 027, **F** +31 (0)499 870 028, **E** info@nhs.eu

www.nhs.eu